



# eurofins



Eurofins E&E CML Limited  
Unit 1 Newport Business Park  
New Port Road  
Ellesmere Port  
CH65 4LZ  
UK

## Certificate of Assessment

**CML 14CA108-1 Issue 1**

- 2 Component **BPG Range of Enclosures**
- |         |              |              |              |              |               |              |
|---------|--------------|--------------|--------------|--------------|---------------|--------------|
|         | <b>BPG1</b>  | <b>BPG2</b>  | <b>BPG3</b>  | <b>BPG4</b>  | <b>BPG4.5</b> | <b>BPG5</b>  |
| Models: | <b>BPG6</b>  | <b>BPG7</b>  | <b>BPG8</b>  | <b>BPG9</b>  | <b>BPG10</b>  | <b>BPG11</b> |
|         | <b>BPG12</b> | <b>BPG13</b> | <b>BPG14</b> | <b>BPG15</b> |               |              |
- 3 Manufacturer **Abtech Limited**
- 4 Address **Sanderson Street  
Lower Don Valley  
Sheffield S9 2UA  
UK**
- 5 The components specified have been evaluated against the requirements of the standard specified in Section 7.
- 6 This evaluation is based on the following documents:  
Report R108A and CML-TR20200609.3
- 7 Specification: **IEC 60529:1989+A1:1999+A2:2013** **BS EN 60529:1992+A2:2013**  
**Petrobras Technical Specification: ET-3010-00-1200-941-PPC-00**
- 8 **IP66W** **IP67** [R108A]  
**IEC 60529:1989+A1:1999+A2:2013** **BS EN 60529:1992+A2:2013**  
**IPX7** [CML-TR20200609.3]
- 9 Assessment This is to certify that, on the basis of the testing carried out, that the above model range of BPG enclosures were considered to comply with the requirements listed in section 8, with respect to the Ingress Protection standards listed in section 7.
- 10 Date: 5<sup>th</sup> February 2014 First issue  
26<sup>th</sup> June 2020 Added IPX7 report

D R Stubbings  
Technical Director