

Certificate of Assessment

- 1 Component **SX Range of enclosures**
- 2 Manufacturer **Abtech Ltd**
- 3 Address **2 Sanderson Street
Lower Don Valley
Sheffield
S9 2UA**
- 4 The components specified have been assessed against the requirements of the standard specified in Section 7.
- 6 This evaluation is based on the following documents:
Certificate IECEx SIR 05.0046U SX Range of enclosures
Tests carried out 7 October 2013
- 7 Specification: **EN 62262:2002** (IEC 62262:2002)
- 8 Impact level: **IK10**
- 9 Assessment:
The products listed in Section 1 have been tested under more onerous conditions, with a 25 mm impact head. The test results are recorded in the project file.
- 10 Date: 7 October 2013

